

CALIFORNIA DEPARTMENT OF FORESTRY & FIRE PROTECTION
OFFICE OF THE STATE FIRE MARSHAL
FIRE ENGINEERING - BUILDING MATERIALS LISTING PROGRAM



LISTING SERVICE

LISTING No. 8110-2336:0501 Page 1 of 1

CATEGORY: 8110 -- DECKING FOR WILDLAND URBAN INTERFACE (W.U.I)

LISTEE: AVM Industries, Inc. 8245 Remmet Ave, Canoga Park, CA 91304
Contact: Amir Rudyan (818) 888-0050
Email: amir@avmindustries.com

DESIGN: Forevercoat 100 Walking Deck System. Product consists of a waterproofing system with a cementitious wear surface installed over polymer modified concrete covering 2.5 lbs/sq. yd. of galvanized metal lath installed over a minimum 5/8" plywood substrate.

Refer to manufacturer's installation instructions and product data sheets.

RATING: *Tested in accordance with ASTM E84 with an additional 20 minute period

Class A
Flame Spread Index: 10
Smoke Developed Index: 10
Max Flame Front: 9 feet

INSTALLATION: In accordance with listee's printed installation instructions, applicable codes and ordinances, and in a manner acceptable to the authority having jurisdiction.

MARKING: Listee's name, model number, rating, and SFM label.

APPROVAL: Listed as decking material for use in the Wildland Urban Interface areas. Refer to listee's Installation Instruction Manual for details.

*Revision 1-5-22 VWW



This listing is based upon technical data submitted by the applicant. CSFM Fire Engineering staff has reviewed the test results and/or other data but does not make an independent verification of any claims. This listing is not an endorsement or recommendation of the item listed. This listing should not be used to verify correct operational requirements or installation criteria. Refer to listee's data sheet, installation instructions and/or other

Date Issued: **July 01, 2021**

Listing Expires **June 30, 2022**

Authorized By: **VICTOR WONG**, Program Coordinator
Fire Engineering Division