BOARD OF **BUILDING AND SAFETY** COMMISSIONERS

> JAVIER NUNEZ PRESIDENT

ELVIN W. MOON VICE PRESIDENT

JOSELYN GEAGA-ROSENTHAL LAUREL GILLETTE GEORGE HOVAGUIMIAN

CITY OF LOS ANGELES CALIFORNIA



ERIC GARCETTI MAYOR

DEPARTMENT OF **BUILDING AND SAFETY** 201 NORTH FIGUEROA STREET LOS ANGELES, CA 90012

OSAMA YOUNAN, P.E. GENERAL MANAGER SUPERINTENDENT OF BUILDING

> JOHN WEIGHT EXECUTIVE OFFICER

AVM Industries, Inc. 8245 Remmet Ave Canoga Park CA 91304 **RESEARCH REPORT: 26206** (CSI # 071300)

Attn: Amir Rudyan (818) 888-0050

Expires: Issued Date: October 01, 2022 Code:

December 01, 2024 2020 LABC

GENERAL APPROVAL – Renewal – Membrane 520 PRO

DETAILS

Aussie Membrane 520 PRO is a single component, cold, liquid-applied polyurethane waterproofing membrane.

The above system is approved for waterproofing when required by Section 1805.3 of the 2020 City of Los Angeles Building Code.

The approval is subject to the following conditions:

- 1. The products shall be delivered to the job site in sealed containers properly identified with the manufacturer's name and trade name.
- Except as specified herein, the application of the system shall be in accordance with the 2. manufacturer's instructions. A copy of the instructions shall be available at each job site.
- 3. The material shall be packaged in standard commercial containers constructed to ensure acceptance by common or other carriers for safe transportation to the point of delivery. Shipping containers shall be marked with the name, type, and quantity of the material contained therein, as defined by the contract or order under which the shipments are made.

RR 26206 Page 1 of 3

AVM Industries, Inc.

- RE: Aussie Membrane 520 PRO
- 4. The date of production shall be marked on each package.
- 5. Application of the product shall be accomplished by an applicator approved by the manufacturer and in writing by the manufacturer.
- 6. All surfaces to receive the product shall be free of large voids, sharp projections, and/or standing water. Prepare surfaces per manufacturer's instructions.
- 7. Complete details for the membrane system shall be submitted for plan check and a building permit shall be obtained.
- 8. Protection for the membrane shall be provided per manufacturer's instruction.
- 9. Prior to placing the concrete slab over the membrane in split-slab applications, the membrane installer shall certify the membrane to be installed according to the manufacturer's specification.
- 10. The above product is approved for below-grade waterproofing as required by Chapter 18 of the Los Angeles Building Code. The product may be used in conjunction with Los Angeles City approved caulking materials at penetrations of the waterproofing membrane.
- 11. The membrane materials shall not be used with pneumatically applied concrete (gunite or shotcrete).
- 12. All surfaces must be smooth, free of depressions, voids, protrusions, clean and free of unapproved curing compounds, form release agents and other surface contaminants.
- 13. The products shall not be used to seal joints or penetrations of fire-rated assemblies. The Aussie Membrane 520 PRO waterproofing membrane is for waterproofing below grade and between slabs when required by Section 1805.3 of the 2020 Los Angeles Building Code.
- 14. The maximum allowable hydrostatic pressure for the Aussie Membrane 520 PRO waterproofing membrane is 17.5 psi with the maximum depth rating of 20 feet.

DISCUSSION

The report is in compliance with the 2020 Los Angeles City Building Code.

The approval is based on tests.

Addressee to whom this Research Report is issued is responsible for providing copies of it, <u>complete with any attachments indicated</u>, to architects, engineers and builders using items approved herein in design or construction which must be approved by Department of Building and Safety Engineers and Inspectors.

RR 26206 Page 2 of 3 AVM Industries, Inc.

RE: Aussie Membrane 520 PRO

This general approval of an equivalent alternate to the Code is only valid where an engineer and/or inspector of this Department has determined that all conditions of this approval have been met in the project in which it is to be used.

EUGENE BARBEAU, Chief Engineering Research Section 201 N. Figueroa St., Room 880 Los Angeles, CA 90012 Phone - 213-202-9812 Email- engineering-research@lacity.org

EB 26206 TLB2200128 R10/05/2022 1805.3

> RR 26206 Page 3 of 3