



**CALIFORNIA DEPARTMENT OF FORESTRY & FIRE PROTECTION
OFFICE OF THE STATE FIRE MARSHAL
FIRE ENGINEERING & INVESTIGATIONS DIVISION
BUILDING MATERIALS LISTING PROGRAM**

LISTING SERVICE

LISTING No.:	8110-2336:0501
CATEGORY:	8110 - DECKING FOR WILDLAND URBAN INTERFACE (W.U.I)
LISTEE:	AVM Industries, Inc. 8245 Remmet Ave, Canoga Park, CA, 91304 Contact: Rudyan, Amir (818) 888-0050 Email: amir@avmindustries.com
DESIGN:	Forevercoat 100 Walking Deck System. Product consists of a waterproofing system with a cementitious wear surface installed over polymer modified concrete covering 2.5 lbs/sq. yd. of galvanized metal lath installed over a minimum 5/8" plywood substrate. Refer to manufacturer's installation instructions and product data sheets.
RATING:	*Tested in accordance with ASTM E84 with an additional 20 minute period Class A Flame Spread Index: 10 Smoke Developed Index: 10 Max Flame Front: 9 feet
INSTALLATION:	In accordance with listee's printed installation instructions, applicable codes and ordinances, and in a manner acceptable to the authority having jurisdiction.
MARKING:	Listee's name, model number, rating, and SFM label.
APPROVAL:	Listed as decking material for use in the Wildland Urban Interface areas. Refer to listee's Installation Instruction Manual for details.
NOTES:	

*Revision 1-5-22
VWW



**CALIFORNIA DEPARTMENT OF FORESTRY & FIRE PROTECTION
OFFICE OF THE STATE FIRE MARSHAL
FIRE ENGINEERING & INVESTIGATIONS DIVISION
BUILDING MATERIALS LISTING PROGRAM**

LISTING SERVICE



This listing is based upon technical data submitted by the applicant. OSFM Fire Engineering staff has reviewed the test results and/or other data but does not make an independent verification of any claims. This listing is not an endorsement or recommendation of the item listed. This listing should not be used to verify correct operational requirements or installation criteria. Refer to listee's data sheet, installation instructions and/or other suitable information sources.

Date Issued: 04/05/2024

Listing Expires: 06/30/2025

Authorized By: **David Castillo**, Program Coordinator
Fire Engineering & Investigations Division