



DEPARTMENT OF REGULATORY AND ECONOMIC RESOURCES (RER)  
BOARD AND CODE ADMINISTRATION DIVISION  
**NOTICE OF ACCEPTANCE (NOA)**

MIAMI-DADE COUNTY  
PRODUCT CONTROL SECTION  
11805 SW 26 Street, Room 208  
Miami, Florida 33175-2474  
T (786) 315-2590 F (786) 315-2599  
[www.miamidade.gov/economy](http://www.miamidade.gov/economy)

**AVM Industries, Inc.**  
8245 Remmet Ave.  
Canoga Park, CA 91304

**SCOPE:**

This NOA is being issued under the applicable rules and regulations governing the use of construction materials. The documentation submitted has been reviewed and accepted by Miami-Dade County RER - Product Control Section to be used in Miami-Dade County and other areas where allowed by the Authority Having Jurisdiction (AHJ).

This NOA shall not be valid after the expiration date stated below. The Miami-Dade County Product Control Section (in Miami-Dade County) and/or the AHJ (in areas other than Miami-Dade County) reserve the right to have this product or material tested for quality assurance purposes. If this product or material fails to perform in the accepted manner, the manufacturer will incur the expense of such testing and the AHJ may immediately revoke, modify, or suspend the use of such product or material within their jurisdiction. RER reserves the right to revoke this acceptance if it is determined by Miami-Dade County Product Control Section that this product or material fails to meet the requirements of the applicable building code.

This product is approved as described herein and has been designed to comply with the Florida Building Code including the High Velocity Hurricane Zone of the Florida Building Code.

**DESCRIPTION: Aussie Membrane 570 Waterproofing System**

**LABELING:** Each unit shall bear a permanent label with the manufacturer's name or logo, city, state and following statement: "Miami-Dade County Product Control Approved", unless otherwise noted herein.

**RENEWAL** of this NOA shall be considered after a renewal application has been filed and there has been no change in the applicable building code negatively affecting the performance of this product.

**TERMINATION** of this NOA will occur after the expiration date or if there has been a revision or change in the materials, use, and/or manufacture of the product or process. Misuse of this NOA as an endorsement of any product, for sales, advertising or any other purposes shall automatically terminate this NOA. Failure to comply with any section of this NOA shall be cause for termination and removal of NOA.

**ADVERTISEMENT:** The NOA number preceded by the words Miami-Dade County, Florida, and followed by the expiration date may be displayed in advertising literature. If any portion of the NOA is displayed, then it shall be done in its entirety.

**INSPECTION:** A copy of this entire NOA shall be provided to the user by the manufacturer or its distributors and shall be available for inspection at the job site at the request of the Building Official.

This NOA consists of pages 1 through 5.

The submitted documentation was reviewed by Jorge L. Acebo.



NOA No.: 22-0929.01  
Expiration Date: 11/30/28  
Approval Date: 11/30/23  
Page 1 of 5

## ROOFING SYSTEM APPROVAL

**Category:** Roofing  
**Sub-Category:** Waterproofing  
**Deck Type:** Concrete  
**Material:** Rubberized Asphalt  
**Maximum Design Pressure:** -290 psf.

### TRADE NAMES OF PRODUCTS MANUFACTURED OR LABELED BY APPLICANT:

<u>Product</u>	<u>Container Sizes</u>	<u>Test Specification</u>	<u>Product Description</u>
Aussie Membrane 570	50 or 30 lbs. Box	CAN/CGSB 37.50-M89	Hot-applied asphalt-based composition membrane applied in a liquid state to form a continuous, fully-adhered waterproofing membrane.
AVM 570 Protection Sheet	39" x 33'	ASTM D6163	Heavy Duty Smooth Surfaced Premium SBS Membrane/Protection Sheet.
Mat 570	3' x 600' Rolls	Proprietary	Reinforcing scrim of spunbonded polyester fibers.
AVM Primer 570-SB	5 gallon pail	Proprietary	Low VOC, solvent-based sprayable primer.

### TRADE NAMES OF PRODUCTS MANUFACTURED BY OTHERS:

<u>Product</u>	<u>Dimensions</u>	<u>Test Specification</u>	<u>Product Description</u>	<u>Manufacturer</u>
Concrete pavers	12" x 12" 2" Thick	ASTM C939	High density concrete pavers.	Generic
Type M Mortar Mix	Various	ASTM C270	Masonry mortar made of a mixture of Portland cement, hydrated lime, and masonry sand.	Generic

### EVIDENCE SUBMITTED:

<u>Test Agency</u>	<u>Test Identifier</u>	<u>Test Name/Report</u>	<u>Date</u>
PRI Construction Materials Technologies	1923T0022	CAN/CGSB 37.50-M89	04/26/22
	1923T0033	ASTM D 6163	09/01/22
	1923T0034	TAS 114 D	09/14/22
	1923T0035	ASTM E 108	08/10/22
	1923T0036	Physical Properties	09/16/22



NOA No.: 22-0929.01  
Expiration Date: 11/30/28  
Approval Date: 11/30/23  
Page 2 of 5

**Deck Type 1** Concrete Decks  
**Deck Description:** Min. 2500 psi  
**System Type F(1):** AVM Aussie 570 Roof Membrane System with Pavers

**All General and System limitations apply.**

**Substrate Preparation:** All surfaces must be dry, smooth, free of depressions, voids, and protrusions, and clean and free of any non-compatible curing compounds, foam release agents and other surface contaminants.

Poured in place concrete must be monolithic, smooth, free of voids, spalled areas, laitance, honeycombs, and sharp protrusions. Precast concrete decks shall be mechanically secured to minimize differential movement and all joints between units shall be grouted.

Concrete around drain shall be depressed to promote positive water drainage.

**Primer:** Apply AVM Primer 570-SB with a flat squeegee or a roller at approximately 400-500 sq.ft./gal. and work well into the substrate to ensure adequate penetration and sealing and puddles are avoided. Allow primer to dry tack free. Base coat must be applied within 72 hours of primer application.

**Base/Top Coat:** A minimum of two coats AVM Aussie System 570 Hot Fluid-Applied Rubberized Asphalt applied to 215mil thickness with Mat 570 reinforcing scrim laid into hot base coat prior to applying the top coat.

**Protection Sheet:** AVM 570 Protection Sheet adhered by laying into hot rubber waterproofing top layer.

**Integrity Test:** Required, and shall be performed in accordance with ASTM D 5957. Water maybe maintained for a period longer than 24 hours if required.

**Inspection:** Contractor and a representative of the membrane manufacturer shall inspect the waterproofing assembly and notify the contractor of any defects. All defects shall be corrected.

**Overburden:** 12 "x 12" x 2" Concrete Pavers installed onto the Protecton sheet with ASTM C270, Type M mortar applied with a 1/2" x 1/2'x 1/2" notched trowel.

**Maximum Design Pressure:** -290 psf. (See General Limitation #9)



**Deck Type 1** Concrete Decks  
**Deck Description:** Min. 2500 psi, dual slab construction  
**System Type F(2):** AVM Aussie 570 Roof Membrane System applied directly to primed substrate with concrete surfacing (Concrete Topping Slabs).

**All General and System limitations apply.**

**Substrate Preparation:** All surfaces must be dry, smooth, free of depressions, voids, and protrusions, and clean and free of any non-compatible curing compounds, foam release agents and other surface contaminants.

Poured in place concrete must be monolithic, smooth, free of voids, spalled areas, laitance, honeycombs, and sharp protrusions. Precast concrete decks shall be mechanically secured to minimize differential movement and all joints between units shall be grouted.

Concrete around drain shall be depressed to promote positive water drainage.

**Primer:** Apply AVM Primer 570-SB with a flat squeegee or a roller at approximately 400-500 sq.ft./gal. and work well into the substrate to ensure adequate penetration and sealing and puddles are avoided. Allow primer to dry tack free. Base coat must be applied within 72 hours of primer application.

**Base/Top Coat:** A minimum of two coats AVM Aussie System 570 Hot Fluid-Applied Rubberized Asphalt applied to 215mil thickness with Mat 570 reinforcing scrim laid into hot base coat prior to applying the top coat.

**Protection Sheet:** AVM 570 Protection Sheet adhered by laying into hot rubber waterproofing top layer.

**Integrity Test:** Required, and shall be performed in accordance with ASTM D 5957. Water maybe maintained for a period longer than 24 hours if required.

**Inspection:** Contractor and a representative of the membrane manufacturer shall inspect the waterproofing assembly and notify the contractor of any defects. All defects shall be corrected.

**Overburden:** Structural Concrete Slab, minimum 2500 psi, in compliance with applicable Building Code.

**Maximum Design Pressure:** N/A (Topping concrete slab shall comply with applicable Building Code requirement.)



## GENERAL LIMITATIONS:

1. Fire classification is not part of this acceptance; refer to a current Approved Roofing Materials Directory for fire ratings of this product.
2. A copy of the integrity test report described herein in accordance with ASTM D5957 shall be provided to the Building Official for review at time of final inspection.
3. All work shall be performed by a Contractor licensed to do roofing/ waterproofing and be a Manufacturer Trained 'Qualified Applicator' approved and licensed by AVM Industries, Inc.. AVM Industries, Inc. shall supply a list of approved applicators to the authority having jurisdiction.
4. Contractor shall submit to the Building Official for review the system specifications and details. Submission of these documents, as well as the proper application and installation of all materials shall be the sole responsibility of the contractor.
5. A non-skid surfacing is required for all pedestrian areas, plaza decks or balconies.
6. Flashings shall be installed according to the manufacturers published standard details, specific details, approved by AVM Industries, Inc., and shall be submitted to the Building Official for review.
7. Perimeter and corner areas shall comply with the enhanced uplift pressure requirements of these areas. Fastener densities shall be increased for both insulation and base sheet as calculated in compliance with Roofing Application Standard RAS 117. Calculations prepared, signed and sealed by a Florida registered Professional Engineer, Registered Architect, or Registered Roof Consultant **(When this limitation is specifically referred within this NOA, General Limitation #9 will not be applicable.)**
8. All attachment and sizing of perimeter nailers, metal profile, and/or flashing termination designs shall conform with Roofing Application Standard RAS 111 and the wind load requirements of applicable Building Code.
9. The maximum designed pressure limitation listed shall be applicable to all roof pressure zones (i.e. field, perimeters, and corners). Neither rational analysis, nor extrapolation shall be permitted for enhanced fastening at enhanced pressure zones (i.e. perimeters, extended corners and corners). **(When this limitation is specifically referred within this NOA, General Limitation #7 will not be applicable.)**
10. Aussie Membrane 570 Waterproofing shall not be installed over lightweight insulating concrete.
11. All products listed herein shall have a quality assurance audit in accordance with the Florida Building Code and Rule 61G20-3 of the Florida Administrative Code.

**END OF THIS ACCEPTANCE**

